



"Beyond Providing Water..."

Republic of the Philippines
SAN FRANCISCO WATER DISTRICT
San Francisco, Agusan del Sur

REQUEST FOR QUOTATION

Date: _____

Name of Establishment: _____
Address: _____
Contact Number: _____


Sir,

Please quote your price at the spaces hereunder corresponding to the articles called for under **Purchase Request No. 2024-06-0192** dated **June 28, 2024** to be delivered at Karaos reservoir within **15 calendar days** from the receipt of Purchase Order.


RUBEN M. JARABATA JR.
BAC Chairperson 7/1/24

ITEM NO.	QTY	UNIT	DESCRIPTION	UNIT PRICE	TOTAL
1	150	Piece	GI BUSHING REDUCER 1 X 3/4" Working Temperature: atleast Minimum -20°C to maximum 300°C FM Approved Fittings: 50 Bar 15 - 100mm – NB, 30 Bar 125 - 150mm - NB Materials: ASTM/ASME A197, EN 1562, ISO 5922, ASTM A47 Fastening thread: ISO228-1 (eg. Backnuts) Galvanizing (where applicable): ZINC Hot Dip Galvanized to minimum of 500gr/m ² , with minimum average thickness of 70 micron Design Test Pressure: atleast 6mm - 100mm (100 Bar), 125mm - 150mm (64 Bar) Price must be VAT Inclusive		
TOTAL					

I HEREBY CERTIFY that the above-listed articles are actually carried on stock by me and that the prices quoted are hereby specified. The terms and conditions of this call are hereby accepted. Time for delivery / pick up is within _____ () calendar days from receipt of the Purchase Order.


LORAINÉ S. CUYUBAO

Canvasser

NAME & SIGNATURE OF BIDDER/DEALER

Nationality