

Reyond Providing Water....

Date:

Republic of the Philippines

SAN FRANCISCO WATER DISTRICT

San Francisco, Agusan del Sur

REQUEST FOR QUOTATION

Address: Contact Number:				_ _ _	
Please quote your price at the spaces hereunder corresponding to the articles called for under Purchase Request No. 2024-09-0275 dated September 3, 2024 to be delivered at SFWD Office within 3 calendar days from the receipt of Purchase Order. RUBEN M. JARABATA JR. BAC Chairperson					
NO.	QTY	UNIT	DESCRIPTION	UNIT PRICE	TOTAL
1	5	ROLL	HDPE PIPE 1-1/4" DIA. X 60M LENGTH Equivalent to 32mm DIA. HDPE PIPE SDR9 Polyehtylene pipes with a design stress of 6.3MPa Nominal Wall Thickness = 3.6mm Must submit product sample Must submit shop drawing Manufacturers must be ISO certified		
· · · · · · · · · · · · · · · · · · ·	priming Advantage (specific particles)		Government Transaction Price inclusive VAT		
TOTAL					
I HEREBY CERTIFY that the above-listed articles are actually carried on stock by me and that the prices quoted are hereby specified. The terms and conditions of this call are hereby accepted. Time for delivery / pick up is within () calendar days from receipt of the Purchase Order. LORAINE SCUYUBAO					
Canvasser				NAME & SIGNATURE BIDDER/DEALER	
				Nationality	